

# Summary Report

**Test ordered by:**

Sabic Innovative Plastics BV  
Plasticslaan 1

4612 PX Bergen op Zoom  
The Netherlands

**Manufacturer:**

Sabic Innovative Plastics BV  
Plasticslaan 1

4612 PX Bergen op Zoom  
The Netherlands

**Test procedures**

ACFI Test Specifications No. 11 Rigid Plastic Sheets  
ACFI Test Specifications No. 00a General Part A  
ACFI Test Specifications No. 00b General Part B  
ACFI Collection of resolutions

**Version**

1.04  
1.03  
1.02  
26

**Date**

01.07.2015  
01.03.2018  
01.12.2018  
08.06.2021

**Model: LEXAN™ THERMOCLEAR™**

**Hail resistance test results:**

Test report	Product	Roof applications			Façade applications		
		Water tightness	Light transmission	Appearance	Water tightness	Light transmission	Appearance
H366	LT2UV102RS17	HW5	HW3	HW1	HW5	HW4	HW1
H357	LT2UV105R175	HW4	HW1	HW1	HW5	HW1	HW1
H365	LT2UV163TS27	HW5	HW3	HW1	HW5	HW3	HW2
H362	LT2UV165X26	HW5	HW3	HW1	HW5	HW4	HW2
H364	LT2UV169X	HW5	HW3	HW1	HW5	HW4	HW2
H359	LT2UV209X	HW5	HW4	HW1	HW5	HW5	HW1
H356	LT2UV205X32	HW3	HW2	HW1	HW4	HW2	HW2
H358	LT2UV259X	HW5	HW4	HW1	HW5	HW4	HW2
H363	LT2UV255X34	HW5	HW3	HW2	HW5	HW4	HW2
H361	LT2UV325X38	HW5	HW3	HW2	HW5	HW4	HW2
H360	LT2UV329X38	HW5	HW3	HW1	HW5	HW3	HW2

Rapperswil, 23. March 2022